



TRJHT12PDP - Front view

C1




TRJHT12PDP - Top view

C1



PHOTOVOLTAIC MODULE




APPROXIMATE DIMENSIONS [mm]

A	1303	E	1500
A1	1264	H	1238
A2	-	H1	1464
B	2384	H2	1521
B1	400	H3	2473
B2	790	Hm	500
B3	1400	C1	38104
S	35	D1	19.052
C1	38104	D2	19.052
-	-	-	-
-	-	-	-
-	-	-	-



TRJHT12PDP  
SIDE VIEW @ 0°

TRJHT12PDP  
SIDE VIEW @ 55°



IDEAL FOUNDATION

IDEAL FOUNDATION



5° MAXIMUM ANGLE ERROR


5° MAXIMUM ANGLE ERROR

FOUNDATION ANGLE ERROR RECOVERY



IDEAL FOUNDATION

IDEAL FOUNDATION




1° MAXIMUM ANGLE ERROR

1° MAXIMUM ANGLE ERROR

PRELIMINARY PV TABLES SPACING

NOMINAL VALUE - IT MAY CHANGE DUE TO MOUNTING TOLERANCES



MATERIAL CHARACTERISTICS

STEEL

Structural steel - at least S235JR - yield strength and thickness in accordance with structural calculations.

SPHERICAL BEARINGS

Bronze / Stainless steel.

SPACERS

Stainless Steel.

SCREWS, NUTS and WASHERS

All steel parts will be galvanized according to environmental conditions of the site to have a design lifetime of 25 years

GALVANIZATION

Basic Option:

All steel parts will be galvanized according to environmental conditions of the site to have a design lifetime of 25 years



12/2023	00	Prima emissione	Francavilla G.	Berardinelli G.	Francavilla G.
DATA	REV	DESCRIZIONE EMISSIONE	PREPARATO	VERIFICATO	APPROVATO
		ID Documento Committente	IMPIANTO: PIANE VOMANO - MORRO D'ORO (TE)		
		CoD.044.FV.BCD.00052			
Logo Appaltatore e Delineazione Commerciale		ID Documento Appaltatore	TITOLO: DETTAGLIO TRACKER_2		
		FV_IR_05.PianeVomano_PD.ELA.52			
deve-loop S.r.l. unipersonale					
FOGLIO	SEGUE	DI	FORMATO		
02	SI	02	A0	DIS. N.	scala: -
NOME FILE:					